




Transverse joint more than 2'-0" clear of drainage inlet wall or no transverse joint



D = Pavement Thickness



1. Refer to Project Plans for location and Type of drainage inlets.
2. Top of inlet shall be flush with shoulder surface.
3. Extend joint filler material to bottom of LCB. Where LCB is not used as base material, the joint filler material shall only extend to the bottom of the new Concrete pavement.
4. For Jointed plain concrete pavement only. For continuous reinforced concrete pavement, terminate pavement steel reinforcement 2" from all edges of longitudinal isolation joint.

DISTANCE X	BARS REQUIRED
2'-0" to 1'-6"	2
1'-6" to 9"	1 @ X/2
9" or less	None

P45